

**AutoMate®
DCS 5000/AutoMax®
Digital I/O Rails
and Modules**

(M/N 45C1A)
(M/N 45C3)
(M/N 45C4)
(M/N 45C5)
(M/N 45C7)
(M/N 45C40)
(M/N 45C42)
(M/N 45C43)
(M/N 45C44)
(M/N 45C46)
(M/N 45C60)
(M/N 45C62)
(M/N 45C63)
(M/N 45C65)
(M/N 45C66A)
(M/N 45C67)
(M/N 45C68)
(M/N 45C69)
(M/N 45C166A)

Industrial

CONTROLS

Instruction Manual J-3012-3

RELIANCE
ELECTRIC 

The information in this user's manual is subject to change without notice.

DANGER

ONLY QUALIFIED ELECTRICAL PERSONNEL FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THIS EQUIPMENT AND THE HAZARDS INVOLVED SHOULD INSTALL, ADJUST, OPERATE, OR SERVICE THIS EQUIPMENT. READ AND UNDERSTAND THIS MANUAL IN ITS ENTIRETY BEFORE PROCEEDING. FAILURE TO OBSERVE THIS PRECAUTION COULD RESULT IN SEVERE BODILY INJURY OR LOSS OF LIFE.

DANGER

THE USER IS RESPONSIBLE FOR CONFORMING TO THE NATIONAL ELECTRIC CODE AND ALL OTHER APPLICABLE LOCAL CODES WITH RESPECT TO WIRING, GROUNDING, DISCONNECTS, AND OVERCURRENT PROTECTION. FAILURE TO OBSERVE THIS PRECAUTION COULD RESULT IN SEVERE BODILY INJURY OR LOSS OF LIFE.

WARNING

A HARDWIRED EMERGENCY STOP CIRCUIT OUTSIDE OF THE PROGRAMMABLE CONTROLLER CIRCUITRY MUST BE PROVIDED. USE AN EXTERNAL STOP CIRCUIT AND THE "READY CONTACT" IN THE PROCESSOR TO STOP THE PROCESS SAFELY IN THE EVENT OF EQUIPMENT FAILURE. FAILURE TO OBSERVE THIS PRECAUTION COULD RESULT IN BODILY INJURY AND/OR DAMAGE TO THE EQUIPMENT.

DANGER

CHECK FOR THE PRESENCE OF VOLTAGE BEFORE YOU PERFORM ANY INSTALLATION OR MAINTENANCE OPERATIONS. THE I/O DEVICES CONNECTED TO THE FIELD WIRING MAY BE POWERED FROM AN EXTERNAL POWER SOURCE. DO NOT ASSUME THAT IT IS SAFE TO WORK ON THE MODULES AND WIRING WHEN JUST THE MAIN SOURCE OF POWER IS DISCONNECTED. DISCONNECT ALL SOURCES OF POWER BEFORE SERVICING THE EQUIPMENT. FAILURE TO OBSERVE THESE PRECAUTIONS COULD RESULT IN SEVERE BODILY INJURY OR LOSS OF LIFE.

WARNING

REMOVING OR INSERTING A MODULE OR I/O INTERCONNECT CABLE WITH POWER APPLIED MAY RESULT IN UNEXPECTED MACHINE MOTION OR LOSS OF PROCESS CONTROL. STOP THE MACHINE OR PROCESS IN AN ORDERLY FASHION AND DISCONNECT THE POWER TO THE SYSTEM BEFORE YOU REMOVE OR INSERT A MODULE OR I/O INTERCONNECT CABLE. FAILURE TO OBSERVE THESE PRECAUTIONS COULD RESULT IN BODILY INJURY.

AutoMax®, AutoMate® and Reliance® are registered trademarks of Reliance Electric Company or its subsidiaries.

Buss® is a registered trademark of Bussman, Cooper Industries.